

# Listing of Positive or Assumed Positive Materials with Remaining Quantity Greater than zero

Site ID California State University, Fullerton

Building ID T700 Carpenter & Key Shop

Suspect Material / Category	Material Location	Asbestos Present
Pipe Insulation  TSI (HM: 08)	ABOVE CEILING IN AFFECTED AREA ON ELBOWS. FLOOR(S): 1	Yes (assumed)
12" x 12" White Floor Tile And Adhesive  Flooring (HM: 04)	IN OFFICE 702A. FLOOR(S): 1	Yes (assumed)
12" x 12" Brown Patterned Floor Tile And Adhesive  Flooring (HM: 07)	IN ROOM 701 AND 702. FLOOR(S): 1	Yes (assumed)
12" x 12" Glued-On, Random Ceiling Tile  Ceilings (HM: 01)	IN ROOM 700. FLOOR(S): 1	Yes (assumed)

# Listing of Positive or Assumed Positive Materials with Remaining Quantity Greater than zero

Site ID California State University, Fullerton

Building ID T1200 Public Safety Bldg

Suspect Material / Category	Material Location	Asbestos Present
4" Baseboard With Baseboard Adhesive	ALONG BASE OF ALL WALLS. FLOOR(S): 1	Yes (assumed)
Flooring (HM: 04)		
12" x 12" Beige With Streaks Floor Tile And Adhesive	HALLS AND RESTROOMS. FLOOR(S): 1	Yes
Flooring (HM: 03)		
Carpet Over Concrete With Carpet Adhesive	OFFICES AND LOBBY. FLOOR(S): 1	Yes (assumed)
Flooring (HM: 05)		
Drywall And Joint Compound	CEILINGS IN HALLWAYS. FLOOR(S): 1	Yes (assumed)
Walls/Ceilings (HM: 02)		
Drywall And Joint Compound	WALLS IN HALLWAYS AND ROOMS. FLOOR(S): 1	Yes (assumed)
Walls/Ceilings (HM: 01)		
2' x 4' Laid-In, Fissured Ceiling Tile	IN ROOMS. FLOOR(S): 1	Yes (assumed)
Ceilings (HM: 06)		

# Listing of Positive or Assumed Positive Materials with Remaining Quantity Greater than zero

Site ID California State University, Fullerton

Building ID T1900 Parking Services

Suspect Material / Category	Material Location	Asbestos Present
9" x 9" Beige With Streaks Floor Tile And Adhesive	THROUGHOUT FLOOR. FLOOR(S): 1	Yes (assumed)
Flooring (HM: 01)		
Ceiling Texturing Compound	ON WOOD CEILINGS THROUGHOUT. FLOOR(S): 1	Yes
Walls (HM: 03)		
Wall Texturing Compound	ON WOOD WALLS THROUGHOUT. FLOOR(S): 1	Yes
Walls (HM: 02)		